



INSPECTION CERTIFICATE Nr 01

BV Ref: 17.IT2535875

Doc. Ref.: TC4308/17/PC/pl

Manufacturer: COMPARATO NELLO S.r.l.
 Viale della Libertà, n° 53 17014 Cairo Montenotte (SV)
Activity requested by: COMPARATO NELLO S.r.l.

SUPPLY / SUBJECT OF INSPECTION	ITEM / Model	QTY
Servocontrol	Universal with ISO 5211 type F07	1

Standard Reference	Description
EN 60529:1991/corr:1993/A1:2000/A2:2013	Degrees of protection provided by enclosures (IP code)

CONCLUSIONS / REMARKS:

The equipment has been tested according to the IP68 requirements of above standard reference EN 60529.
 The tests have been carried out by the following Testing laboratory on samples provided by the original equipment manufacturer.

Testing laboratory: ELETTRA S.r.l. - Via Matteucci, 10 - 50041 Calenzano.

Date(s) of testing and/or inspection: 27th February 2017 and 27th October 2017

Laboratory tests report annexes to this certificate:

- IP6X: refer to ELETTRA S.r.l. n° R-IP-248-0217-01A test report;
- IPX8: refer to ELETTRA S.r.l. n° R-IP-248-1017-03A test I report;

Results

The equipment object of this report has been found in compliance with IP68 requirements as per EN 60529.

The undersigned, inspector to Bureau Veritas, certifies that the hereabove mentioned supply was inspected in conformity with the applicable requirements of the purchase order and the contractual requirements

Prepared by:

Name: P. Lama

Signature:



Checked by:

Name: P. Capellini

Signature:

Date of issue: 13/11/2017

Inspection centre: Bureau Veritas Italy – Technical Compliance Business Unit